



Stantec Architecture Inc.  
1344 South Flores Street Suite 201  
San Antonio TX 78204-1672  
Tel: (210) 223-9588  
Fax: (210) 223-9589

## ADDENDUM #6

07/25/2014

TO PLANS AND SPECIFICATIONS FOR  
**RENOVATION AND ADDITION TO**  
**FT. SAM HOUSTON ELEMENTARY SCHOOL**  
**&**  
**RENOVATION AT COLE HIGH SCHOOL**

Ft. Sam Houston  
San Antonio, TX

**NOTE:**

If you have questions about this project, please contact:  
Edward Rodriguez, Project Manager at SHW Group, LLP.  
210.223.9588  
[erodriguez@shwgroup.com](mailto:erodriguez@shwgroup.com)

or

Wanira Magaloni  
[wmagaloni@shwgroup.com](mailto:wmagaloni@shwgroup.com)


This Addendum is generally separated into sections for convenience; however, all contractors, subcontractors, material suppliers and other involved parties shall be responsible for reading the entire Addendum. Failure to list an item(s) in all affected sections of this Addendum does not relieve any party affected from performing per instructions, provided the information is set forth one time anywhere in the Addendum.

This document shall become attached to and part of the Construction Documents for the aforementioned project.

**BID DATE and TIME: REVISED AS NOTED BELOW**

**DELIVER PROPOSALS TO:**

**Office of SHW Group, LLP**  
1344 South Flores Street  
Suite 201  
San Antonio, Texas 78204



07.25.2014

**GENERAL ITEMS:**

1. The bid date has been revised to **Thursday, July 31, 2014 at 2:30 pm**

**ELEMENTARY SCHOOL**

1. Sheet E401: CLARIFICATION – the externally mounted SPD for panels “7B” and “7C” shall be 100kA in lieu of 600kA.

**END OF ADDENDUM #6**